

Directorate of Urban Administration and Development, M.P. Bhopal

Check List (53 Points) of fire Installation proposal/Plan

(Fire NOC)

1	Name of the building	THE VEDANSH INTERNATIONAL SCHOOL (RUN BY AKSHARAARAMBH EDUCATION SOCIETY)
2	Address of the Building	PLOT NO. IGI-SP-01, INDORE GREENS AT VILLAGE NAINOD, TEHSIL AND DISTRICT INDORE (MP)
3	Name and Address of builder/promoter	EMAAR INDIA LIMITED EMAAR CONTINENTAL CITY, OFF SUPER CORRIDOR EXTENSION ROAD, NAINOD, INDORE (MP)
4	Name and Address of owner/occupiers of Individual Flats.	NAND CIVILTECH PRIVATE LIMITED, 5/27, MAHESH NAGAR, INDORE (MP)
5	Plot Area a. Title b. Land use (in case of residential building Indicate no. of dwelling units)	27801.90 SQM EDUCATIONAL BUILDING
6	Covered area (at grade level)	6064.79 SQM & 750 SQM
7	Height of the building	11.70 Mtr
8	a. Overall height (from grade level) b. Approved/Provisional set back areas conforming to building bye-laws are as follows : Front- Back – Left Side – Right Side –	11.70 Mtr. 12.00 M 7.50 M 7.50 M 7.50 M
9	a. Number of basements (Please Indicate level below grade in each case) b. If basement extends beyond the building line, please indicate the load bearing strength of the roof of basement. c. Area of basement d. Whether any piazza is proposed? If so, details of the level of piazza and ramps etc. be indicated	NO
10	Number of Floors (including ground floor)	SPORTS BLOCK – LG + UG + 2 ACADEMIC + ADMIN – G + 2
11	Occupancy (Use-please mention separately for basement & floors)	EDUCATIONAL
12	Covered area of typical floor of bldg. Blocks.	ACADEMIC + ADMIN 13490.03 SQM SPORTS BLOCK 1876.53 SQM
13	Parking areas (please give details)	BASEMENT PARKING 7730.00 SQM
14	Details of surrounding property features	EAST – Other's Land WEST – Other's Land

For Nand Civil Tech Pvt. Ltd.,


Authorised Signatory.

		NORTH – Other's Land SOUTH – Road
15	Approach to proposed building, width of the road and connecting roads, if any	20 M WIDE ROAD
16	Please give details of water supply available exclusively for fire fighting.	Water Tank, WATER SUPPLY
17	Has wet riser(s) been provided? If so, please indicate the number of risers and internal dia of each.	NA
18	Has any down comer been provided? If so, please give details.	YES AS PER FIRE PLAN
19	Please indicate the present arrangement for replenishment of water for fire fighting.	25000 liter water tank
20	Is a public or other water storage facility available nearby? If so, please give the capacity and distance from your building, also please indicate if it is readily accessible.	NA
21	Please give any other information that you can, regarding available of water supply for fire fighting.	Tube Well & water tank
22	Have internal hydrants been provided If so, please indicate no. of hydrants on each floor including basement(s) and terrace.	YES AS PER FIRE PLAN
23	Have first add-hose reels been provided? If so, please indicate: a. No. of hose reels on each floor including basement(s) b. Bore and length of hose-reel tubing on each reel. c. Size (bore) and type of nozzle fitted to each hose reel. d. Is the hose reel connected directly to the riser or to the hydrant outlet?	Yes AS PER FIRE PLAN HOSE REELS 01 No. 25 MM 30 mtr. 5 MM Shut Off Nozzle Yes
24	Has fire hose been provided near each hydrant? If so, please indicate a. The type of hoses b. The size (bore) of hoses. c. The length of each hose d. Total number of hoses provided near each hydrant.	Yes, PROPOSED 63 MM 15 MTR 02 NOS.
25	Have branch pipes been provided? If so, please Indicate a. The type of branch pipes b. Size of nozzle fitted to each branch	YES, PROPOSED
26	a. If the basement is used for car parking or storage, has it been sprinkled? b. Whether any cubicals proposed in the basement? If so, the area of each cubical be indicated? c. Whether segregation/compartimentation of the basement has been provided? If so, please indicate	YES AS PER FIRE PLAN
27	Is the building equipped with automatic fire detection and alarm system? If so, please indicate: a. The type of detectors used b. The standard to which the detectors confirm c. The code to which the installation confirms.	NA
28	Have manual call boxes been installed in the building for raising an alarm in the event of an outbreak of fire? If so, please give details	Yes , Manual Call Point With Hooter Provided
29	Has public address system been provided between the various floors and the fire control room in entrance lobby?	YES
30	Has an intercom system been provided between the various floors and the fire control room in entrance of the building?	Yes

For Nand Civiltech Pvt. Ltd.,

Authorised Signatory.



31	Has a fire control room be provided in the entrance lobby of the building?	NA
32	How many staircases have been provided in the building? Please indicate in each case: a. Width of the stairway b. Width of the treads c. Height of the rigors d. if the treads are of the non-slip type.	02 Nos. 1500MM 300 MM 150 MM NON SLIP TYPE
33	What is the average occupant load per floor?	200-300 person approx.
34	How many lifts have been installed in the building? Please indicate in each case. a. The floors between which the lift runs. b. The type of doors fitted to the lift car and at each landing c. Fire resistance rating of lift car and landing doors, if known. d. Floor area of the lift car. e. Loading capacity of the lift car. f. Has communication system been installed in the lift for car? g. Has a Fireman's switch been installed in the lift for grounding it in the event of fire?	No
35	Have any stationary fire pump(s) been installed for pressurizing the wet riser? If so, please indicate a. The number of pumps b. The size of suction and delivery connection of each pump c. The output of each pump. d. The maximum head against which the pump can operate at the output mentioned at (c) e. Is the pump automatic in action?	YES a. 02 Nos. b. 100 & 63 MM c. 1620 & 180 LPM d. 35 MTR e. YES
36	Has a standby source of power supply been provided? Lift is through a generator, please indicate a. the capacity (output) b. the functions that can be maintained simultaneously by the use of generator, such as operating lift(s) fire pumps emergency lighting etc. c. Is the generator automatic in action or has to be started manually?	YES, PROPOSED ALL EMERGENCY SERVICES AUTOMATIC
37	Has any yard hydrant been provided from the building's fire pump?	YES, PROPOSED
38	Where more than one lifts are installed in a common enclosure have individual lifts been separated by fire resisting walls or 2 hours fire rating?	YES, PROPOSED
39	Has the lift shaft(s) lift lobby or stairwell been pressurized? If so, give details.	No
40	Have the lift lobbies and staircase been effectively enclosed to prevent fire/smoke entering them from outside at any floor?	YES, PROPOSED
41	Have all exists and direction of travel to each exit been sign-posted with illuminated signs?	YES, PROPOSED
42	Has a false ceiling been provided in any portion of the building? If so, please indicate location and also mention if	YES PROPOSED Noncombustible type material will be

For No


	the material used for the false ceiling is combustible or noncombustible.	used.
43	<p>Is the building centrally air-conditioned? If so, please indicate</p> <p>a. The material used for construction of duct and its fittings.</p> <p>b. The type of tinning used for ducts, if any</p> <p>c. The type of lagging used, if any for insulating any portion of the duct, please also indicate how the lagging is secured.</p> <p>d. If false ceiling is provided, please give information as at 42 above</p> <p>e. If plenum is used a return air passage has it been protected with fire detectors? Please give details.</p> <p>f. Has a separate AHU been provided for each floor?</p> <p>g. Whether automatic shut down of AHU is coupled with detection system?</p> <p>h. Is the ducting for each floor effectively isolated or is it continuous or more than one floors?</p> <p>i. Are the fire dampers being provided?</p>	No
44	<p>Where are the switchgear and transformers located? If inside the building, please indicate.</p> <p>a. If the switchgear and transformer(s) have been housed in separate compartments, effectively separated from each other and from other portion of the buildings by a four hours fire resistive wall?</p> <p>b. What precautions have been taken to prevent a possible fire in the transformer(s) from spreading?</p>	Outside the building.
45	<p>I Where electric cables, telephone cables, dry/wet risers/down comers pass through a floor or wall have the spaces (apertures) round the cables/pipes been effectively sealed/plugged with non-combustible, fire resistant material?</p> <p>II Ventilation</p> <p>a. Whether natural ventilation is relied upon? If so give details of the vents for the stairwell, lift shaft.</p> <p>b. Whether mechanic ventilation has been proposed? If so, give details of the proposed system indicating the number of air changes for the basement and other floors.</p> <p>c. Whether mechanical ventilation is coupled with automatic detection system? Please give details of the system.</p>	<p>YES</p> <p>NA</p> <p>NA</p> <p>N.A.</p>
46	Please indicate the number and type of fire extinguishers provided at various indications and the arrangement for the maintenance of the extinguishers.	As per IS: 2190 ABC powder type (4 kg) 02 Nos. on each floor and CO2 type (2 kg) 02 Nos. on each floor PROPOSED
47	Please indicate if all fire extinguishers bear the ISI certification mark.	YES
48	Whether the refuge area has been provided? If so, the floor on which provided and the total area provided floor-wise.	N.A.
49	Are the occupants of the building systematically trained in fire prevention, use of fire extinguishers and emergency procedures? If so, please give details.	YES, PROPOSED
50	Does an emergency organization exist in the building? If so,	YES, PROPOSED

for Nand Civil Tech Pvt. Ltd.,

Authorised Signatory.

	please give details and append a copy of the emergency (Fire) orders	
51	Has a qualified Fire Officer been appointed for the building either individually or jointly with other building(s)	YES, PROPOSED
52	Has the building been protected against lightening? If so, does the lightening protect confirm to any code? Please indicate details.	YES, PROPOSED As per IS: 2309-1989
53	The work has not been started on site and construction will be started only after final approval of the Competent Authority the position of construction site is given below:	Building Under Construction

For Nand Civil Tech Pvt. Ltd.,


Authorised Signatory.

Owner's Signatures

Signature of the Applicant/Fire Consultant

Name

Name

(in block letters)

Designation

Date-----

Organisation

Mobile No.

Mobile No.

E-mail ID